



Ref. Certif. No.

DK-59770-A1-UL

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST
CERTIFICATES FOR ELECTRICAL EQUIPMENT
(IECEE) CB SCHEMESYSTEME CEI D'ACCEPTATION MUTUELLE DE
CERTIFICATS D'ESSAIS DES EQUIPEMENTS
ELECTRIQUES (IECEE) METHODE OC

CB TEST CERTIFICATE

Product
ProduitName and address of the applicant
Nom et adresse du demandeurName and address of the manufacturer
Nom et adresse du fabricantName and address of the factory
Nom et adresse de l'usineNote: When more than one factory, please report on page 2
Note: Lorsque il y plus d'une usine, veuillez utiliser la 2^{ème} pageRatings and principal characteristics
Valeurs nominales et caractéristiques principalesTrademark (if any)
Marque de fabrique (si elle existe)
Type of Manufacturer's Testing Laboratories used
Type de programme du laboratoire d'essais constructeurModel / Type Ref.
Ref. De typeAdditional information (if necessary may also be
reported on page 2)
Les informations complémentaires (si nécessaire,,
peuvent être indiqués sur la 2^{ème} pageA sample of the product was tested and found
to be in conformity with
Un échantillon de ce produit a été essayé et a été
considéré conforme à laAs shown in the Test Report Ref. No. which forms part
of this Certificate
Comme indiqué dans le Rapport d'essais numéro de
référence qui constitue partie de ce Certificat

CERTIFICAT D'ESSAI OC

Recessed luminaire

COELUX SRL
Via Cavour 2
Lomazzo, 22074 Co ItalyCOELUX SRL
Via Cavour 2
Lomazzo, 22074 Co Italy☐ Additional Information on page 2

100-240 V~ 50/60Hz 300 W IP20

CoeLux S.r.l.

CoeLux® 45 HC, CoeLux® 45 LC, CoeLux® 45 SQUARE,
CoeLux® 60 HC☒ Additional Information on page 2

IEC 60598-1(ed.8), IEC 60598-2-2(ed.3)

3245662.918777 issued on 2017-02-15

This CB Test Certificate is issued by the National Certification Body
Ce Certificat d'essai OC est établi par l'Organisme **National de Certification**Date: 2017-02-17
Original Issue Date: 2016-11-25

Signature:

Jan-Erik Storgaard

- ☐ UL (US), 333 Pfingsten Rd IL 60062, Northbrook, USA
☒ UL (Demko), Borupvang 5A DK-2750 Ballerup, DENMARK
☐ UL (JP), Marunouchi Trust Tower Main Building 6F, 1-8-3 Marunouchi, Chiyoda-ku, Tokyo 100-0005, JAPAN
☐ UL (CA), 7 Underwriters Road, Toronto, M1R 3B4 Ontario, CANADA

For full legal entity names see www.ul.com/ncbnames



Ref. Certif. No.

DK-59770-A1-UL

Additional Information:

Also investigated to EN 60598-2-2:2012 and EN 60598-1:2015

National Differences specified in the CB Test Report

The original report was modified to include the following changes/additions:

- Added two new models CoeLux® 45 SQUARE and CoeLux® 60 HC;
- Updated ANNEX 1 for some missing information about cables and controlgear certificates;
- Fuses (F1, F2, F3) not deemed necessary in this kind of construction, have been removed from LED module. Fault condition tests has been repeated without these fuses;
- Manual instruction updated for better explanation of power supply connection;
- Addition of the Particular requirements according to National Deviations of Republic of Korea.

Additional information (if necessary)

Information complémentaire (si nécessaire)



☐ UL (US), 333 Pfingsten Rd IL 60062, Northbrook, USA

☒ UL (Demko), Borupvang 5A DK-2750 Ballerup, DENMARK

☐ UL (JP), Marunouchi Trust Tower Main Building 6F, 1-8-3 Marunouchi, Chiyoda-ku, Tokyo 100-0005, JAPAN

☐ UL (CA), 7 Underwriters Road, Toronto, M1R 3B4 Ontario, CANADA

For full legal entity names see www.ul.com/ncbnames

Date: 2017-02-17

Original Issue Date: 2016-11-25

Signature:

Jan-Erik Storgaard